



कार्यालय नगर निगम जयपुर

(पण्डित दीनदयाल उपाध्याय भवन, लालकोठी, टॉक रोड जयपुर-302015, राजस्थान)

क्रमांक :- एफ.31()मु.स्वा.अधि./नगिज/2026-27/164

दिनांक :- 30-6-2026

SAFE DRINKING WATER AND SANITARY CONDITIONS CERTIFICATE

It is certified that an inspection team headed by Dr. Rashmi Kankaria, Chief Health Officer from Nagar Nigam Jaipur inspected the **ASIAN WORLD SCHOOL, NEAR HANGING GARDEN, JAISINGHPURA, AJMER ROAD, JAIPUR**, on 04-05-2026 and on the basis of the Water Test Report (Attached) bearing no 4865 dated 19-01-2026 certified that the **ASIAN WORLD SCHOOL**, has safe drinking water facilities for the students and members of staff of the institution, School is maintaining the hygienic sanitation condition in the building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The Certificate is valid upto 31 March. 2027.

(Dr. Rashmi Kankaria)
Chief Health Officer
Nagar Nigam Jaipur

To,

The Principal,
ASIAN WORLD SCHOOL,
NEAR HANGING GARDEN, JAISINGHPURA, AJMER ROAD, JAIPUR,

Signature valid

D/Dr.Rashmi Kakariya/All Letter

RajKaj Ref No.:
23108218

M e-Sign



Digitally signed by Rashmi Kankaria
Designation : Chief Health Officer
Date: 2026.06.30 15:11:59 IST
Reason: Approved

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2025-2026/4865

Date: 19/1/26

To,

Principal
Asian World School .
Medical Hiub.
Jaisinghpura.Mansarowar EXT:
Ajmer Road. Jaipur

The Sample was not Collected
by this Laboratory

Not Valid for water
quality legal Cases

Your Letter No-Nil dated 06/01/2026
Date of Receipt 06/01/2026

Particulars			RO Water
	value as per I.S.:10500/2012		Asian World School .
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			06/01 /2026
Date of Examination			06/01 /2026
Lab. Sample No.			P-163
1. pH	6.5-8.5	6.5-8.5	6.84
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	30
6. Total Hardness (as CaCo3) mg/l	200	600	20
7. Calcium (as Ca) mg/l	75	200	3
8. Magnesium (as Mg) mg/l	30	100	3
9. Chloride (as Cl-) mg/l	250	1000	10
10. Nitrates (as NO3-) mg/l	45	45	4
11.Sulphate(as So4-2)mg/l	200	400	1
12. Total Dissolved Solids mg/l	500	2000	75
13.Fluoride mg/l	1.00	1.5	0.10
14.Iron mg/l	1.0	No Relaxation	Nil
15.Arsenic mg/l	0.01	No Relaxation	Nil

Remark- 1. All chemical parameters except pH are in mg/l
2. Tested Results Relate only to The Samples send by you

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2025-2026/
Copy to:- 1.The Chief Chemist, PHED Raj. Jaipur

Date:

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur